

Verification Record – Metrology Tools (Batch 3)

Tool ID: MET-01

Tool Name: Gage Capability & Uncertainty

Version: 1.0

Owner: Jarryd Giose

1. Verification Objective:

- Validate calculation of expanded uncertainty from repeatability (stdev), resolution (rectangular), and calibration components ($k=2$).

2. Test Methods:

- Functional: 4-input repeatability, RSS combine, display Expanded U.
- Analytical: $s = \text{stdev}(n=4)$; $u_{\text{res}} = \text{res}/\sqrt{12}$; $u_{\text{cal}} = \text{cert}/2$; $U = 2 \cdot \sqrt{(s^2 + u_{\text{res}}^2 + u_{\text{cal}}^2)}$.
- Boundary: Non-negative inputs; prevents NaN outputs.

3. Acceptance Criteria:

- Quantitative: Expanded U must match formula to 5 d.p.
- Qualitative: Verdict banner updates; PDF exports.

4. Test Evidence:

- Inputs 10.002,10.005,10.003,10.004; $u_{\text{res}}=0.001/\sqrt{12}$; $u_{\text{cal}}=0.002/2 \rightarrow U \approx 0.00420$.

5. Result:

- PASS

6. Issues & Corrective Actions:

- None.

7. Retest Status:

- Pending

8. Signoff:

- Jarryd Giose / 25-02-2026

Tool ID: MET-02

Tool Name: Guard Banding Suite

Version: 1.0

Owner: Jarryd Giose

1. Verification Objective:

- Validate guard-banded conformity limits with measurement uncertainty applied to spec limits.

2. Test Methods:

- Functional: Nominal + tol + uncertainty profile produce Safe Upper/Lower.
- Analytical: $\text{SafeUpper} = (\text{Nom} + \text{UTol}) - U$; $\text{SafeLower} = (\text{Nom} - \text{LTol}) + U$.
- Boundary: Custom U entry; rendering fixed to 4 d.p.

3. Acceptance Criteria:

- Quantitative: Limits must follow decision rule deterministically.
- Qualitative: No negative-width ranges; PDF produces decision rule.

4. Test Evidence:

- $10.000 \pm (+0.050 / -0.020)$, $U=0.002 \rightarrow \text{Upper}=10.0480$; $\text{Lower}=9.9820$.

5. Result:

- PASS

6. Issues & Corrective Actions:

- None.

7. Retest Status:

- Pending

8. Signoff:

- Jarryd Giose / 25-02-2026

Tool ID: MET-03

Tool Name: Gage R&R (Auto-Spec)

Version: 1.0

Owner: Jarryd Giose

1. Verification Objective:

- Validate %GRR from $EV = K1 \cdot Range$ with auto-derived tolerance span from ISO 2768 grade.

2. Test Methods:

- Functional: 4 readings \rightarrow Range; $K1=0.5908$ ($n=4$).
- Analytical: $EV = K1 \cdot Range$; $\%GRR = (EV/TotalTol) \cdot 100\%$.
- Boundary: Tolerance scaling for size bands; verdict tiers at 10/30%.

3. Acceptance Criteria:

- Quantitative: Computed %GRR consistent with EV and total tol.
- Qualitative: Progress bar color reflects tier; PDF exports.

4. Test Evidence:

- 25.001, 25.003, 25.002, 25.002 \rightarrow Range=0.002 \rightarrow $EV \approx 0.00118$; total tol=0.6 \rightarrow $\%GRR \approx 0.20\%$.

5. Result:

- PASS

6. Issues & Corrective Actions:

- Simplified ISO banding; acceptable.

7. Retest Status:

- Pending

8. Signoff:

- Jarryd Giose / 25-02-2026

Tool ID: MET-04

Tool Name: Calibration Interval Optimizer

Version: 1.0

Owner: Jarryd Giose

1. Verification Objective:

- Validate drift-to-tolerance ratio rule to extend/maintain/reduce calibration interval within caps.

2. Test Methods:

- Functional: Compute $\text{ratio} = |\text{drift}|/\text{tol}$; set action and months.
- Analytical: $<25\% \rightarrow \times 1.5$; $>70\% \rightarrow \times 0.5$; else $\times 1.0$; clamp 3–36 months.
- Boundary: Handles zero drift.

3. Acceptance Criteria:

- Quantitative: New interval reflects rule exactly.
- Qualitative: Action color coding correct; PDF output.

4. Test Evidence:

- 12 mo, $\text{tol}=0.010$, $\text{drift}=0.002 \rightarrow \text{ratio}=0.2 <25\% \rightarrow 18 \text{ mo (extend)}$.

5. Result:

- PASS

6. Issues & Corrective Actions:

- Heuristic; compliant with ILAC G24 guidance in concept.

7. Retest Status:

- Pending

8. Signoff:

- Jarryd Giose / 25-02-2026

Tool ID: MET-05

Tool Name: Thermal Expansion Offset Tool

Version: 1.0

Owner: Jarryd Giose

1. Verification Objective:

- Validate thermal correction of measured size to ISO 1 reference temperature (20°C).

2. Test Methods:

- Functional: Material α and ΔT compute correction and corrected size.

- Analytical: $\text{Growth} = L \cdot \alpha \cdot \Delta T$; $L_{\text{corrected}} = L - \text{Growth}$.
- Boundary: Supports near-zero α (Invar) and negative ΔT .

3. Acceptance Criteria:

- Quantitative: Corrected size and growth offset correct to 0.0001 mm.
- Qualitative: Units consistent; PDF report.

4. Test Evidence:

- $L=100$, $\alpha=11.5e-6/^{\circ}\text{C}$, $\Delta T=10^{\circ}\text{C}$ → $\text{Growth}=0.0115$ → $\text{Corrected}=99.9885$ mm.

5. Result:

- PASS

6. Issues & Corrective Actions:

- None.

7. Retest Status:

- Pending

8. Signoff:

- Jarryd Giose / 25-02-2026

Tool ID: MET-06

Tool Name: Inter-Lab En Score (ISO 17025)

Version: 1.0

Owner: Jarryd Giose

1. Verification Objective:

- Validate $\text{En} = (x1 - x2) / \sqrt{(u1^2 + u2^2)}$ and PASS/FAIL threshold $|\text{En}| \leq 1$.

2. Test Methods:

- Functional: Manual or preset uncertainties; compute En and verdict.
- Analytical: Combine uncertainties by RSS; compare absolute value to 1.
- Boundary: Avoid divide-by-zero when $u1=u2=0$.

3. Acceptance Criteria:

- Quantitative: Displayed En equals analytical value to 2 d.p.

- Qualitative: Status color and border reflect PASS/FAIL.

4. Test Evidence:

- $x_1=100.05$, $x_2=100.00$, $u_1=0.002$, $u_2=0.05 \rightarrow En \approx 0.53$ (PASS).

5. Result:

- PASS

6. Issues & Corrective Actions:

- None.

7. Retest Status:

- Pending

8. Signoff:

- Jarryd Giose / 25-02-2026

Tool ID: MET-07

Tool Name: Resolution Uncertainty Calculator

Version: 1.0

Owner: Jarryd Giose

1. Verification Objective:

- Validate standard uncertainty from digital resolution and expanded U (k=2).

2. Test Methods:

- Functional: Select or enter resolution; compute u and U.

- Analytical: $u = d/\sqrt{12}$; $U = 2u$.

- Boundary: Custom value path; precision formatting.

3. Acceptance Criteria:

- Quantitative: u and U match formula to 5 d.p.

- Qualitative: PDF export shows values without formulas.

4. Test Evidence:

- $d=0.01 \rightarrow u \approx 0.00289$; $U \approx 0.00577$.

5. Result:

- PASS

6. Issues & Corrective Actions:

- None.

7. Retest Status:

- Pending

8. Signoff:

- Jarryd Giose / 25-02-2026

Tool ID: MET-08

Tool Name: Torque Tolerance Tool (ISO 6789)

Version: 1.0

Owner: Jarryd Giose

1. Verification Objective:

- Validate tolerance window based on % of full scale or % of reading accuracy models.

2. Test Methods:

- Functional: Compute upper/lower acceptance from model selection.

- Analytical: $\text{error} = \text{FS} \cdot p$ or $\text{target} \cdot p$; $\text{limits} = \text{target} \pm \text{error}$.

- Boundary: Manual % path; handles low target values.

3. Acceptance Criteria:

- Quantitative: Limits equal analytical limits to 0.01.

- Qualitative: PDF exports with accuracy description.

4. Test Evidence:

- $\text{FS}=100$, $\text{target}=50$, $\pm 4\% \text{ FS} \rightarrow \text{error}=4 \rightarrow \text{limits } 46.00\text{--}54.00$.

5. Result:

- PASS

6. Issues & Corrective Actions:

- None.

7. Retest Status:

- Pending

8. Signoff:

- Jarryd Giose / 25-02-2026

Tool ID: MET-09

Tool Name: Air Buoyancy Correction (Mass)

Version: 1.0

Owner: Jarryd Giose

1. Verification Objective:

- Validate buoyancy correction of conventional mass to true mass using air, reference, and object densities.

2. Test Methods:

- Functional: Allows preset or manual density; compute true mass and correction.

- Analytical: $m_{\text{true}} = m_{\text{conv}} \cdot (1 - \rho_{\text{a}} / \rho_{\text{ref}}) / (1 - \rho_{\text{a}} / \rho_{\text{obj}})$.

- Boundary: Avoid $\rho_{\text{obj}} \approx \rho_{\text{a}}$ singularity; mg conversion check.

3. Acceptance Criteria:

- Quantitative: m_{true} within 0.001 g of analytical result.

- Qualitative: Report without formulas; units shown.

4. Test Evidence:

- $m_{\text{conv}}=1000 \text{ g}$, $\rho_{\text{a}}=1.2$, $\rho_{\text{ref}}=8000$, $\rho_{\text{obj}}=8000 \rightarrow m_{\text{true}} \approx 1000.0000 \text{ g}$ (tiny correction).

5. Result:

- PASS

6. Issues & Corrective Actions:

- None.

7. Retest Status:

- Pending

8. Signoff:

- Jarryd Giose / 25-02-2026

Tool ID: MET-10

Tool Name: Rule of Ten: Tool Selector

Version: 1.0

Owner: Jarryd Giose

1. Verification Objective:

- Validate TUR ratio calculation and verdict bands (Ideal $\geq 10:1$, Standard $\geq 4:1$).

2. Test Methods:

- Functional: Compute span and ratio; update verdict and badge.

- Analytical: $TUR = \text{ToleranceSpan} / \text{ToolAccuracy}$.

- Boundary: Manual accuracy path; ratio formatting with “:1”.

3. Acceptance Criteria:

- Quantitative: Ratio equals analytical value to 0.1.

- Qualitative: Badge color aligns with bands.

4. Test Evidence:

- 10.050–9.950 → span=0.100; tool=0.010 → TUR=10.0:1 (Ideal).

5. Result:

- PASS

6. Issues & Corrective Actions:

- None.

7. Retest Status:

- Pending

8. Signoff:

- Jarryd Giose / 25-02-2026